

# Alabama Department of Transportation - Proposal Questions and Answers

Project Number NH-0215(506)

Call # 021

County

TUSCALOOSA

## Project Description

for constructing the Planing, Resurfacing, and Traffic Stripe on SR-215 (Veterans Memorial Parkway) from the junction of 10th Avenue East to the junction of the Traditions Condominiums Entrance in Tuscaloosa. Length 1.719 mi. In the County of TUSCALOOSA, State of Alabama.

As of: 11/16/2022

Item	Question	Answer
1	Deep Patching - 500 LBS. - To be done after planning 3.0" NOTES: 202 & 203 Planed area must be covered thru the Upper Binder Layer by end of work day. Doing the Deep Patching and Upper Binder where it is required by the end of the work day is not possible. It appears that the Deep Patching must be done separately to make it work.	After careful review, it has been determined that work is to be performed as shown in the current plan set.
2	In addition to the question concerning deep patching and putting back 500 LBS of lower binder and then cover it with 190 LBS of upper binder in same days operation. How will this meet the ALDOT SPEC? Three lifts of asphalt in same days operation on top of each other	After careful review, it has been determined that work is to be performed as shown in the current plan set. Additionally, the longest patch is 350 LF. Using estimated production rates (observed from previous projects), we believe one lane could be milled, patched, and upper binder placed in one day's operation. Also, it is of our opinion that a day's patching length can be reduced and the total work can be spread over multiple days.
3		
4		
5		
6		
7		