

Alabama Department of Transportation - Proposal Questions and Answers

Project Number HPP-TAPBH-CMAQ-A104(916)

Call # 003

County

JEFFERSON

Project Description

For constructing the Pedestrian Bridge and Sidewalks over SR-3 (US-31) near Wald Park in Vestavia Hills. Length 0.104 mi. In the County of JEFFERSON, State of Alabama.

As of: 2/20/2024

Item	Question	Answer
1	Should the time be adjusted for some of the Bridge Construction?	After careful consideration, the Department saw fit to adjust the Working Time for this project and revise Project Specific Special Provision 22-PS0300.
2	The plans (per sheet 24W) call for 2x2 mesh, however, there is a mention of anti-climb, which is typically .5" x 3". Please clarify if a 2x2 wired mesh that is not anti-climb will be acceptable.	Removed the callout for Anti-climb mesh from Sheet 24W and added FLAG 1. Added FLAG 1 on the Index Sheet. Modified the 22-PS0264 Vertical Transportation Tower special provision to remove the reference to Anti-climb mesh.
3	Please also provide clarification on how the panels will be connected to the bridge. I've attached a sample drawing of what we have previously supplied for ALDOT projects, and would like to know if providing this detail for the bridge will be acceptable for the project.	The panels will be connected using the detail shown on sheet 24V.
4		
5		
6		
7		